

## Roy Romanow Provincial Laboratory Environmental Services

5 Research Drive Regina, Saskatchewan S4S 0A4

(306) 787-7138 / (306) 787-3140

## **Environmental Services Analysis Report - Final**

Invoice Number:2187226Collected Date:12-Jun-20237:30 AMSample Location:Village WellReceived:13-Jun-20239:24 AMCollected by:Steve NasbyReported:14-Jun-202310:36 AM

Premise #: Water Source: Well

Submitted By: Invoice:

KIVIMAA VILLAGE OF
MOONLIGHT BAY
BOX 120
LIVELONG, SK

KIVIMAA VILLAGE OF
MOONLIGHT BAY
BOX 120
LIVELONG, SK

LIVELONG, SK

SOM 1J0 SOM 1J0

Test Unit **Analysis** Result Sask Guideline Comment **Fee** Regular Panel 23.00 **Total Coliform** 3 orgs/100 mL No orgs/100 mL 1 E. Coli orgs/100 mL No orgs/100 mL Absent 2

Submitter Phone Number: 306-845-3336 Emailed results to: rvkmb@littleloon.ca

## Comments:

- 1. Testing results indicates that your water is unacceptable for human consumption.
- 2. See above for comment

2180 23rd Avenue

Regina, Saskatchewan

Tax Summary

G.S.T. (reg # 89583 0180 RT001)

S4S 0A5

Amount Received: (Mastercard) 23.00

Refund to be issued by the Department of Finance.

Balance \$0.00

Contact Us:

Result Interpretation: Please contact your Prairie North Public Health Officer at: (306) 446-6400

Billing Inquiries: Phone: 1-833-989-5353, Email: shaar@saskhealthauthority.ca

The following data was provided by the submitter. The Environmental Services Lab does not guarantee the accuracy of the

results.

Free Chlorine: Total Chlorine: Turbidity:

1.10